


Number	18-001154-PR01 (NW-K20-06-en-01)
Owner	YAVUZ COMPANY d.o.o. Cehaje bb 75350 Srebrenik Bosnia-Herzegovina
Product	Plastic profile, profile combination: casement member - frame member
Designation	System: PVC profile BAUFENS 7 chambers
Details	Material Polyvinyl Chloride unplasticized (PVC-U); Projected width 124 mm; Structural depth 85 mm; Casement member: Designation BF 8502 - 7 chambers ; Cross section (W x T) 84 mm x 85 mm; Thickness of infill 24 mm; Edge cover of infill 26 mm; Reinforcement material Steel - galvanized Steel; Reinforcement designation BF8502-0; Frame member: Designation BF 8501 - 7 chambers ; Cross section (W x T) 74 mm x 85 mm; Reinforcement material Steel - galvanized Steel; Reinforcement designation BF8501-0
Special features	

Result	Thermal transmittance according to EN 12412-2:2003-07  $U_f = 1,1 \text{ W/(m}^2\text{K)}$
--------	---


#### Basis \*)

EN 12412-2:2003-07

\*) and corresponding national versions  
e.g. DIN EN)

Test report: 18-001154-PR01 PB-K20-06-en-01

#### Representation



The test was done without insulating glass unit.

#### Instructions for use

The results obtained can be used as evidence in accordance with the above basis.

#### Validity

There is no time limit.

When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

The data and results given relate solely to the tested/described specimen. This test/evaluation does not allow any statement to be made on further characteristics of the present structure regarding performance and quality.

#### Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim

19.11.2018



Manuel Demel, M.BP, Dipl.-Ing. (FH)  
Deputy Head of Testing Department  
Building Physics



Konrad Huber, Dipl.-Ing. (FH)  
Operating Testing Officer  
Building Physics

Identity-Check



[www.ift-rosenheim.de/ift-aepueft](http://www.ift-rosenheim.de/ift-aepueft)  
ID: 4B7-06AF9